

## ADDENDUM NO. 1

**Project: South Tower Tank Rehabilitation – City of Petersburg, IL**

**Bid Opening: 10:00 AM, Thursday, November 9, 2017**

**Engineer: Klingner & Associates**

**Date: November 3, 2017**

**To: Prospective Bidders**

---

This addendum forms a part of the bidding and contract documents and modifies the original bidding documents dated October 12, 2017. Acknowledge receipt of the addendum in the space provided on the Bid Form.

### **To the Project Manual:**

#### **Section 011100 – SUMMARY OF WORK**

##### 1.4 WORK COVERED BY CONTRACT DOCUMENTS

A. The Work of Project is defined by the Contract Documents and consists of the following:

Delete paragraph A.1 and substitute the following:

1. Cleaning of all surfaces using the Society for Protective Coatings Standard, *SSPC-SP WJ-4/NACE WJ-4 Light Waterjetting*, which is a low-pressure water cleaning (LP WC) method.

#### **Section 099800 – WATER STORAGE TANK PAINTING AND COATING**

##### PART 3 - EXECUTION

##### 3.5 PAINTING SCHEDULE

B. Steel Tank Interior and Exterior

1. System Cleaning

Delete paragraphs 2 and 3 and substitute the following.

2. Follow *SSPC-SP WJ-4/NACE WJ-4 Light Waterjetting*, which is a low-pressure water cleaning (LP WC) method
3. Water cleaning performed at pressures less than 34 MPa (5,000psig).
4. Visible deposits of oil, grease, foreign matter, and other contaminants shall be removed by waterjet cleaning of all surfaces.

END OF ADDENDUM NO. 1